25X1

FORM 697 REV. 3-53

25X1

INTERDEPARTMENTAL CORRESPONDENCE

25X1

25X1

TO:

DATE: 10 June 1958

25X1

25X1

SUBJECT: POWER FOR   TERMINALS

25X1

The amperage and computed volt-amperes necessary to run three of the four terminals are given below. We did not measure the   terminal (Receive RF Terminal) before it was shipped.

25X1

Terminal	Cabinet	Amperes	Volt Amperes
Transmit Data	Audio	4.4	515
	Control	9.5	1110
	Reader	7.2	842
	Crypto	9.5	1110
Transmit RF	Control	9.5	1110
	Pulse	7.3	853
Receive Data	Control	9.5	1110
	Pulse	7.0	818
	Punch	2.0	234
	Crypto	9.5	1110
	Printer	40	4680

25X1

25X1

Voltampere calculations were based on a 117 volt line.

25X1

25X1